

On the recyclability of used refrigerants using a mobile IR-device with IoT capabilities

Nikolaos Argirusis^{1,*}, Georgia Sourkouni², and Christos Argirusis^{2,3}

¹ mat4nrg GmbH, 38678 Clausthal-Zellerfeld, Germany

² Clausthal Centre of Materials Technology (CZM), Clausthal University of Technology, 38678 Clausthal Zellerfeld, Germany

³ School of Chemical Engineering, National Technical University of Athens (NTUA), 15773 Zografou-Athens, Greece

Keywords: refrigerants, recycling, IR-sensors, mobile detection, IoT

Presenting author email: nikos.argirusis@mat4nrg.de

Climate change is a serious problem caused primarily by the use of fossil fuels, although greenhouse gas (GHG) emissions are also regarded as a major contributor. Globally, greenhouse gas emissions cause an increase in average temperature, a decrease in ice mass, which causes sea level rise, and extreme climate events. Surface temperature has risen by 1.4 °C since the 1900s, with an exceptional increase of 0.18 °C predicted for June 2023 (Rohde 2023).

Fluorinated greenhouse gases (FGGs) are categorized as global pollutants. Most fluorinated greenhouse gases have an extremely high global warming potential (GWP) when compared to other greenhouse gases (Hansen et al., 2010). Historically, chlorofluorocarbons (CFCs) have been utilized as propellants for packaging materials, aerosol solvents, and refrigerants, and they have been identified as potential contributors to ozone depletion (Wallington et al., 1994). The Montreal Protocol of 1987 agreed to eliminate the use of CFCs. This led to the replacement of CFCs with hydrofluorocarbons (HFCs) (Sheraz et al., 2021). As a result of recent changes in environmental legislation, new refrigerant categories have evolved, with the goal of making refrigerant gases "greener" in terms of their impact on the ozone layer.

It is critical to be able to detect the existence and concentration of these new gases, as well as older gases, in order to evaluate if the systems are operational and whether they can be recycled or destroyed. Additional reasons why quantitative measurements of the presence of such gases are required include: Leak detection during the manufacturing of air conditioning components to ensure that they are leak-free, as well as testing newer systems to ensure that they are running at maximum efficiency and mixing ratios.

Fast Fourier transform spectroscopy can be utilized for detection and quantification. However, this equipment is sensitive, heavy, and expensive, and they frequently require the assistance of a skilled technician while operating in the field. As a result, a mobile, user-friendly, and cost-effective detecting equipment would be beneficial.

In this paper, we report a detailed study on the classification of refrigerant gases in IoT-based gas detection systems.

Through experimental assessments, we demonstrate the advantages of our machine learning approach in accurately discriminating between important refrigerant gases, including R32 and R134, with low latency.

Data was collected using a range of widely available refrigerant gases. In this work, we use data from the refrigerants R32 and R134A. Therefore, thorough IR-spectra of the individual refrigerants are required. These were achieved utilizing an in-house 3D-printed tubular reactor with two BaF₂ windows, which can be integrated into the beamline of a Bruker IR-Spectrometer.

The data collecting process required exposing the IR-sensor to controlled gas environments containing refrigerant gases at various concentrations using precisely produced gas combinations. The sensors were calibrated before to each experiment to provide precise and consistent measurements. Following the measurement, data were immediately sent to an IoT platform and made available to B2B clients.

Acknowledgement

This research received funding through the project "Circular economy ecosystem to Recover, Recycle and Re-use F-gases contributing to the depletion of greenhouse gases (LIFE Retradables) from the LIFE Programme of the European Union under grant agreement LIFE19 CCM/AT 001226 - LIFE Retradables.

References

June 2023 Temperature Update Posted on July 11, 2023 by Robert Rohde, [https://berkeleyearth.org/june-2023-temperature-update/#:~:text=The%20global%20mean%20temperature%20in,C%20\(0.27%20°F\)](https://berkeleyearth.org/june-2023-temperature-update/#:~:text=The%20global%20mean%20temperature%20in,C%20(0.27%20°F)).

Hansen J, Ruedy R, Sato M and Lo K, Global surface temperature change. Rev Geophys 48 (2010). <https://doi.org/10.1029/2010RG000345>

Wallington TJ, Schneider WF, Worsnop DR, et al., The environmental impact of CFC replacements – HFCs and HCFCs. *Environ Sci Technol.* 320A (1994). <https://doi.org/10.1021/es00056a714>

The Montreal Protocol. UN Environment Programme available at:

<https://www.unenvironment.org/ozonaction/who-we-are/about-montreal-protocol> as read on 06. August 2023.

Mahshab Sheraz, Ali Anus, Van Cam Thi Le et al., A comprehensive review of contemporary strategies and approaches for the treatment of HFC-134a, *Greenhouse. Gas. Sci. Technol.* 11:1118–1133 (2021);

<https://doi.org/10.1002/ghg.2113>